

January 31st, 2026

Mr. Jean-François Durocher

Water Compliance Officer
Drinking Water and Environmental Compliance Division
Ministry of the Environment, Conservation and Parks

Subject:

2025 – Annual and Summary Report for the Limoges Drinking Water System

Dear Mr. Durocher:

Please see attached, the annual and summary report for the Limoges Drinking Water System that covers the period from **January 1st, 2025, to December 31, 2025.**

This document has been prepared in accordance with Sections 11 and 22 of Ontario Regulation 170/03 under the *Safe Drinking Water Act, 2002*. The Annual Report and Summary Report for the Limoges Drinking Water System are due by February 28, 2026.

The Annual Report includes:

- A summary of the water system's compliance with applicable legislation and regulations.
- A description of any adverse water quality incidents and corrective actions taken.

The Summary Report includes:


1. The quantities and flow rates of water supplied to consumers served by the Limoges Drinking Water System, including monthly averages.
2. A comparison of these values to the system's rated capacity to ensure compliance with regulatory requirements.

This report is also distributed to the Members of the Municipal Council.

Sincerely,



Prepared by,
Sébastien Cadieux
Senior Operator/Compliance Officer
scadieux@nationmun.ca



Approved by,
Nicholas Pigeon, CET
Water & Wastewater Director, ORO
npigeon@nationmun.ca



Revised by,
Sébastien Mainville
Water and Wastewater Manager
smainville@nationmun.ca

In preparing this document, which includes both the Annual Report and the Summary Report, we have complied with the following requirements under Ontario Regulation 170/03:

- Identified any instances of non-compliance with the *Safe Drinking Water Act, 2002*, the Regulation, the system's approval, the Drinking Water Works Permit, the Municipal Drinking Water License, and any applicable orders during the reporting period.
- Specified the duration of each non-compliance event and the corrective actions taken (as required for both reports).
- Summarized the quantities and flow rates of water supplied, including monthly averages and maximum daily flows (as required for the Summary Report).
- Compared the flow summary to the system's rated capacity as outlined in the system approval, Drinking Water Works Permit, or Municipal Drinking Water License, or—if applicable—an agreement with another system under subsection 5(4) (Summary Report requirement).
- Included information on adverse water quality incidents and measures taken to address them (Annual Report requirement).

Comparison:

During the period of January 1, 2025, to December 31, 2025:

- The maximum daily flow to the distribution system was **2142 m³/day**. This occurred in July. On that day, **1441 m³** came from the Water Treatment Plant and **477 m³** from Cheney (Clarence-Rockland).
The total water from the wells was **1544m³** which represents **74%** of the rated capacity of 2080 m³/day, from our PTTW.
- The maximum daily flow from the wells was **1921 m³/day**. This occurred in June, and it represented 92% of the rated capacity. In accordance with our PTTW # P-300-6203976113, the maximum rated flow from the wells is **24.1 L/sec or 2080 m³/day**.
- The average daily distribution flow was **1448 m³/day**.
 - During summer (May 1st to October 31st) months, the average daily distribution flow was **1598 m³**.
 - During winter (January, February, March, April, November and December) months, the average daily distribution flow was **1297 m³**.
- *The Total water taking from the City of Clarence-Rockland* was **153848 m³**, for an average of **422 m³/day**.



Drinking - Water Systems Regulation O. Reg.170/03

System Information

Drinking Water System Name:	Limoges Water Treatment Plant
Drinking Water System Number:	260006841
Drinking Water System Owner:	The Corporation of the Nation Municipality
Operating Authority:	The Nation Municipality
Drinking Water System Category:	Large Municipal Residential
Period being reported:	Jan. 1 to Dec. 31, 2025

Does your Drinking-Water System serve more than 10 000 people?

Yes () No (X)

Is your annual report available to the public at no charge on a web site on the internet?

Yes (X) No ()

Summary Report (170/03 Schedule 22) will be available for inspection at:

The Nation municipality website

List all Drinking-Water System, which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Le Baron Estate	N/A

Did you provide a copy of your annual report to all Drinking Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes (X) No ()

Limoges Drinking Water System

Ontario Regulation 170/03, Section 11 Annual Report 2025

Indicate how you notified system users that your annual report is available, and is free of charge.

(X) Public access / Notice via the web

() Public access / notice via government Office

() Public access / notice via a newspaper

() Public access / notice via Public Request

() Public access / notice via a Public Library

() Public access / notice via another method _____

Describe your Drinking Water System

The Limoges water treatment plant was designed as a GUDI Treatment System. It is operated as a GUDI System; treating groundwater that has the potential of being influenced by surface water. The treatment uses a conventional process; chemically assisted filtration followed by disinfection. The plant has a rated capacity of 2080 m3/day; services the Village of Limoges, the Community of Forest Park, Le Baron Estate, and the Ben Tardif Trailer Park. Raw water is supplied from two production wells; delivered via a five km watermain into an aeration basin at the water treatment plant. Further treatment is achieved in sequence by chemical oxidation and a dual train chemically assisted filtration process. Primary disinfection is achieved by chlorination followed by chloramination for secondary disinfection. Treated water is stored in two onsite water storage reservoirs and then pumped into the distribution system. The Limoges drinking water system is also being supplied with chloraminated water from the Rockland WTP in the City of Clarence-Rockland. A 10 km transmission watermain supplies water to the LWTP from Cheney. The water first reaches the Re-chlorination building north of Limoges which consists of : a chemical feed system designed to boost the chloramine level, one flow meter, two CL2 analyzers (before and after chemical injection) and one standby power generator. Water is then directed to LWTP and into the two water storage towers. All processes are fully automated and monitored using a SCADA System. Operators perform routine monitoring, and maintain operation and production records of the groundwater supply wells, the plant and treatment processes, and the distribution systems. The Operators also conduct water quality sampling and testing, and system maintenance. The system operates under the MDWL 179-102 and the DWWP 179-202.

The Chemical feed systems consist of chemical pumps, storage tanks, piping and associated appurtances to deliver treatment chemicals including potassium permanganate, Alum, Polyelectrolyte, Sodium Hypochlorite and Ammonium Sulphate.

List all water treatment chemicals used over this reporting period

Chemical Name	Supplier
Potassium Permanganate	Brenntag
PAX-XL6	Kemira
Polyelectrolyte	Northland Chemicals Inc.
Sodium Hypochlorite	Brenntag
Ammonium Sulfate	Brenntag

Were any significant expenses incurred to?

() Install required equipment

() Repair required equipment

(X) Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Calibration of flow meter	\$	4,700.00
Hydrant inspection & flushing	\$	5,200.00
Calibration of analysers and instruments	\$	2,400.00
Replaced pump #3 at Forest Park booster	\$	48,000.00
Replaced all 3 booster pumps at the LWTP	\$	454,000.00
Greatario reservoir inspection	\$	7,000.00
Well inspection and repair	\$	35,000.00
Replaced check valve at Forest Park booster	\$	1,500.00
Reservoir (East) maintenance	\$	38,000.00

Provide information on the notices submitted under subsection 18(1) of the Safe Drinking Water Act, section 16-4 of Schedule 16 of O.Reg. 170/03, or any Adverse Water Quality Incidents (AWQIs), other observations and non-compliance that occurred during the reporting year and were reported to the Spills Action Centre.

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of samples	Range of E.Coli Or Fecal Results	Range of Total Coliform Results	Number of HPC samples	Range of HPC Results
		(min#)-(max#)	(min#)-(max#)		(min#)-(max#)
Raw Well # 1	52	0 - 0	0 - 0	N/A	N/A
Raw Well # 2	52	0 - 0	0 - 0	N/A	N/A
Treated	52	0 - 0	0 - 0	52	0
Distribution	259	0 - 0	0 - 0	103	0 - 2

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab samples	Range of Results (min#)-(max#)	For continuous monitors use 8760 as the number of samples.
Turbidity (Raw W1)	26	(0.20) - (15.10)	
Turbidity (Raw W2)	26	(0.31) - (2.93)	
Chlorine Combined POE,	8760	(1.16) - (2.84)	
Chlorine Combined POE,	184	(2.10) - (2.34)	
Chlorine Combined distribution	8760	(1.06) - (2.28)	
Chlorine Combined distribution	304	(0.52) - (2.41)	
Turbidity (Treated water)	187	(0.01) - (0.73)	
Turbidity (Treated water)	8760	(0.05) - (0.57)	
Note: Record the unit of measure if it is not milligrams per liter. *Average per day of combine chlorine in distribution system			

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of Legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample date	Result value (mg/L)	Limit (mg/L)	Exceedance
Antimony	2025-04-08	<0.0001	0.006	No
Arsenic	2025-04-08	<0.0001	0.01	No
Barium	2025-01-21	0.480	1	No
Barium	2025-04-08	0.408	1	No
Barium	2025-07-15	0.449	1	No
Barium	2025-10-07	0.497	1	No
Boron	2025-10-07	0.04	5	No
Cadmium	2025-10-07	<0.000015	0.005	No
Calcium	2025-10-07	58.1		
Chromium	2025-10-07	<0.001	0.05	No
Fluoride	<i>to be sampled in 2029</i>		1.5	
Hardness	2025-04-08	267		
Iron	2025-04-08	0.875		
Magnesium	2025-04-08	17.4		
Manganese	2025-04-08	0.125		
Mercury	2025-04-08	<0.00002	0.001	No
Selenium	2025-04-08	<0.001	0.05	No
Sodium	<i>to be sampled in 2029</i>		Health >20 reportable (Limit: 200)	
Uranium	2025-04-08	< 0.00005	0.02	No
Nitrite	2025-01-21	<0.05	1	No
Nitrite	2025-04-08	<0.05	1	No
Nitrite	2025-07-15	0.07	1	No
Nitrite	2025-10-07	<0.05	1	No
Nitrate	2025-01-21	0.32	10	No
Nitrate	2025-04-08	0.30	10	No
Nitrate	2025-07-15	0.26	10	No
Nitrate	2025-10-07	0.24	10	No

Summary of Lead testing under Schedule 15.1 during this reporting period

Location Type	Number of samples	Limit	Range of Lead Results (mg/L)		Number of Exceedance
			(min #) - (max #)		
Plumbing	N/A				N/A
Distribution	6	0.1 mg/L	< 0.00002	0.0002	No
Alkalinity	6		182	193	N/A
pH	6		(7.83 - 8.18)		No

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample date	Result value (µg/L)	Conversion in mg/L	Limit (mg/L)	Exceedance
Alachlor	2025-04-08	0.3	0.0003	0.005	no
Atrazine + N-dealkylated metabolites	2025-04-08	0.5	0.0005	0.005	no
Azinphos-methyl	2025-04-08	1	0.0010	0.02	no
Benzene	2025-04-08	0.5	0.0005	0.001	no
Benzo(a)pyrene	2025-04-08	0.06	0.0001	0.00001	no
Bromoxynil	2025-04-08	0.5	0.0005	0.005	no
Carbaryl	2025-04-08	3	0.0030	0.09	no
Carbofuran	2025-04-08	1	0.0010	0.09	no
Carbon Tetrachloride	2025-04-08	0.2	0.0002	0.002	no
Chlorpyrifos	2025-04-08	0.5	0.0005	0.09	no
Diazinon	2025-04-08	1	0.0010	0.02	no
Dicamba	2025-04-08	1	0.0010	0.12	no
1,2-Dichlorobenzene	2025-04-08	0.5	0.0005	0.2	no
1,4-Dichlorobenzene	2025-04-08	0.5	0.0005	0.005	no
1,2-Dichloroethane	2025-04-08	0.5	0.0005	0.005	no
1,1-Dichloroethylene (vinylidene chloride)	2025-04-08	0.5	0.0005	0.014	no
Dichloromethane	2025-04-08	5	0.0050	0.05	no
2-4 Dichlorophenol	2025-04-08	0.2	0.0002	0.9	no
2,4-Dichlorophenoxy acetic acid (2,4-D)	2025-04-08	1	0.0010	0.1	no
Diclofop-methyl	2025-04-08	0.9	0.0009	0.009	no
Dimethoate	2025-04-08	1	0.0010	0.02	no
Diquat	2025-04-08	5	0.0050	0.07	no
Diuron	2025-04-08	5	0.0050	0.15	no
Glyphosate	2025-04-08	25	0.0250	0.28	no
Malathion	2025-04-08	5	0.0050	0.19	no
2-Methyl-4-chlorophenoxyacetic acid (MCP)	2025-04-08	10	0.0100	0.1	no
Metholachlor	2025-04-08	3	0.0030	0.05	no
Metribuzin	2025-04-08	3	0.0030	0.08	no
Monochlorobenzene	2025-04-08	0.5	0.0005	0.08	no
Paraquat	2025-04-08	1	0.0010	0.01	no
Pentachlorophenol	2025-04-08	0.2	0.0002	0.06	no
Phorate	2025-04-08	0.3	0.0003	0.002	no
Picloram	2025-04-08	5	0.0050	0.19	no

Limoges Drinking Water System

Ontario Regulation 170/03, Section 11 Annual Report 2025

Parameter	Sample date	Result value (µg/L)	Conversion in (mg/L)	Limit (mg/L)	Exceedance
Polychlorinated Biphenyls (PCB)	2025-04-08	0.05	0.0001	0.003	no
Prometryne	2025-04-08	0.1	0.0001	0.001	no
Simazine	2025-04-08	0.5	0.0005	0.01	no
Terbufos	2025-04-08	0.5	0.0005	0.001	no
Tetrachloroethylene	2025-04-08	0.5	0.0005	0.01	no
2,3,4,6- Tetrachlorophenol	2025-04-08	0.2	0.0002	0.1	no
Triallate	2025-04-08	10	0.0100	0.23	no
Trichloroethylene	2025-04-08	0.5	0.0005	0.005	no
2,4,6- Trichlorophenol	2025-04-08	0.2	0.0002	0.005	no
Trifluralin	2025-04-08	0.5	0.0005	0.045	no
Vinyl Chloride	2025-04-08	0.2	0.0002	0.001	no
Trihalomethanes (THM)	2025 RAA	36.25	0.036	0.1 mg/L	no
Haloacetic acids (HAA)	2025 RAA	24.33	0.024	0.08 mg/L	no

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of measure	Date of sample
Chloramines	2.84 (max value)	mg/L	Jan - Dec (May 5th, 2025)

Limoges Drinking Water System

Ontario Regulation 170/03, Section 11 Annual Report 2025

2025 Summary Report - Limoges Water Taking

Municipality: The Nation municipality

Facility: Limoges Water Treatment Plant and Distribution system

Classification: Class 2 Water Distribution

Water Source: Ground Water

Total Designated Capacity (m3/day): 2080

Rated Capacity (L/sec) & (L/min): 24 1440

Well # 1

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	SUM
Total Hours of Taking	401.59	425.00	413.88	315.03	456.77	572.83	543.08	564.65	468.18	430.42	424.63	483.71	
Total Amount of Taking (m3)	16796	16480	18628	14746	17786	22418	24335	23279	18421	22610	17061	20158	232718
Average Daily Taking (m3)	542	589	601	492	574	747	785	751	614	729	569	650	
% Rated Capacity (ave. daily Flow)	26.0%	28.3%	28.9%	23.6%	27.6%	35.9%	37.7%	36.1%	30%	35%	27%	31%	
Max Daily Flow (m3)	623	949	1018	586	726	947	975	924	782	1222	789	864	
% Rated Capacity (max daily Flow)	29.9%	45.6%	49.0%	28.2%	34.9%	45.5%	46.9%	44.4%	38%	59%	38%	42%	
Min Daily Flow (m3)	430	372	302	350	451	556	557	535	476	5	49	429	
% Rated Capacity (min daily Flow)	20.7%	17.9%	14.5%	16.8%	21.7%	26.7%	26.8%	25.7%	23%	0%	2%	21%	
Average Daily Rate of Taking (L/s)	11.73	10.95	12.07	11.58	10.60	10.78	12.16	11.24	10.81	14.72	11.07	11.40	
Peak Daily Rate of Taking (L/s)	23.41	13.32	1348.00	14.48	12.84	15.50	13.38	12.89	12.55	23.66	15.53	15.59	
% Peak Daily Rate of Taking (L/s)	97.5%	55.5%	5616.7%	60.3%	53.5%	64.6%	55.8%	53.7%	52%	99%	65%	65%	
Peak Daily Rate of Taking (L/min)	1405	799	80880	869	770	930	803	773	753	1419.6	931.8	935.4	
% Peak Daily Rate of Taking (L/min)	97.5%	55.5%	5616.7%	60.3%	53.5%	64.6%	55.8%	53.7%	52.3%	98.6%	64.7%	65.0%	
Well level (Static & Dynamic) Avg	7.21	6.91	6.88	7.81	7.79	7.28	6.85	6.44	6.13	5.77	5.79	5.87	
Min Well level (Dynamic)	6.79	6.55	6.41	7.18	7.36	6.84	6.44	5.57	5.79	5.24	5.45	5.45	
Max Well level (Static)	7.48	7.35	7.46	8.15	8.12	7.77	7.14	12.45	6.36	85.82	6.20	6.21	

Well # 2

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	SUM
Total Hours of Taking	399.68	342.35	407.06	312.98	456.17	571.07	540.23	563.12	468.32	339.94	466.70	476.29	
Total Amount of Taking (m3)	16154	13483	17006	14611	18523	22840	22627	21205	16861	13216	17537	19326	213387
Average Daily Taking (m3)	521	482	549	487	598	761	730	684	562	426	585	623	
% Rated Capacity (ave. daily Flow)	25.1%	23.2%	26.4%	23.4%	28.7%	36.6%	35.1%	32.9%	27.0%	20.5%	28.1%	30.0%	
Max Daily Flow (m3)	611	788	958	594	773	975	930	872	702	850	815	822	
% Rated Capacity (max daily Flow)	29.4%	37.9%	46.1%	28.6%	37.2%	46.9%	44.7%	41.9%	33.8%	40.9%	39.2%	39.5%	
Min Daily Flow (m3)	420	0	271	360	460	592	542	479	459	0	48	406	
% Rated Capacity (min daily Flow)	20.2%	0.0%	13.0%	17.3%	22.1%	28.5%	26.1%	23.0%	22.1%	0.0%	2.3%	19.5%	
Average Daily Rate of Taking (L/s)	11.0	10.5	11.1	11.6	11.1	11.0	11.5	10.3	9.9	8.3	11.4	11.1	
Peak Daily Rate of Taking (L/s)	13.7	13.3	13.1	24.6	12.9	13.4	16.4	11.9	11.2	21.6	14.3	14.7	
% Peak Daily Rate of Taking (L/s)	57.1%	55.3%	54.6%	102.5%	53.5%	55.7%	68.1%	49.6%	46.6%	90.0%	59.4%	61.4%	
Peak Daily Rate of Taking (L/min)	822	796	787	1477	771	802	981	715	671	1296	856	884	
% Peak Daily Rate of Taking (L/min)	57.1%	55.3%	54.6%	102.5%	53.5%	55.7%	68.1%	49.6%	46.6%	90.0%	59.4%	61.4%	
Well level (Static & Dynamic) Avg	7.15	6.87	6.81	7.76	7.74	7.22	6.69	6.21	6.07	5.75	5.69	5.95	
Min Well level (Dynamic)	6.72	6.48	6.34	7.12	7.29	6.78	6.37	5.91	5.70	5.31	5.34	5.36	
Max Well level (Static)	7.43	7.30	7.90	8.11	8.08	7.73	7.09	6.64	10.16	587.00	6.10	6.11	

Total Amount of Taking (m3)

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	Avg.
Total Amount of Taking (m3)	32950	29962	35633	29357	36309	45258	46962	44483	35282	35826	34598	39484	
Average Daily Taking (m3)	1063	1070	1149	979	1171	1509	1515	1435	1176	1156	1153	1274	

2025 Summary Report - Limoges Water Distribution System

Municipality: The Nation municipality
Facility: Limoges Water Treatment Plant and Distribution system
Classification: Class 2 Water Distribution
Water Source: Ground Water

Serviced Population: 5900
 Total Designed Capacity (m3/day): 2080

JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	SUM
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Distribution System / Flows

POE - Flows (m3/day)

Avg.	1255	1278	1248	1349	1508	1782	1772	1685	1451	1434	1343	1309
Max.	1382	1440	1404	1462	1701	2091	2142	1962	1680	1808	1489	1563
Min.	1183	1181	1143	1241	1357	1565	1429	1365	1320	1313	1100	1056
Total	38890	35778	38689	40467	46763	53449	54939	52248	43530	44450	40276	40575

Water taken from Clarence-Rockland (transmission main)

Avg.	355.17	367.58	300.11	526.94	518.00	486.88	470.98	468.90	458.72	460.17	343.53	300.02
Max.	360.56	749.63	501.85	541.72	525.83	511.58	482.10	477.71	466.68	910.26	405.68	423.09
Min.	315.02	0.00	0.00	485.74	511.28	428.74	431.11	449.38	454.20	140.03	93.66	0.00
Total	11010	10292	9303	15808	16058	14607	14600	14536	13762	14265	10306	9301

Forest Park - Booster - Flows (m3/day)

Avg.	130.51	130.35	131.47	138.19	152.55	165.00	140.62	138.89	130.06	91.31	122.45	128.11
Max.	163.03	156.98	157.05	187.28	196.21	195.04	179.69	187.93	154.96	150.04	164.65	190.11
Min.	113.62	95.44	117.66	104.30	121.84	125.37	105.17	104.01	62.04	0.00	95.12	97.29
Total	4046	3650	4076	4146	4729	4950	4359	4306	3902	2830	3674	3971

Distribution System / Health - Chlorine Residuals POE - Online

Minimum Total Cl2 (mg/L)

Avg.	2.33	2.39	2.39	2.44	2.31	2.39	2.33	2.39	2.31	2.21	2.36	2.43
Min.	1.63	2.16	2.24	2.33	1.67	2.04	1.25	1.89	2.19	2.08	1.89	2.24

Maximum Total Cl2 (mg/L)

Avg.	2.53	2.56	2.54	2.57	2.59	2.56	2.51	2.53	2.44	2.35	2.56	2.63
Max.	2.63	2.63	2.65	2.68	2.94	2.74	2.63	2.62	2.58	2.51	2.73	2.83

Minimum Free Cl2 (mg/L)

Avg.	0.09	0.09	0.08	0.06	0.07	0.08	0.08	0.08	0.08	0.07	0.06	0.05
Min.	0.07	0.07	0.06	0.05	0.06	0.06	0.07	0.07	0.07	0.06	0.05	0.04

Maximum Free Cl2 (mg/L)

Avg.	0.14	0.13	0.13	0.10	0.11	0.12	0.12	0.12	0.12	0.12	0.10	0.10
Max.	0.16	0.16	0.17	0.11	0.17	0.13	0.13	0.14	0.13	0.14	0.11	0.12

Minimum Combined Cl2 (mg/L)

Avg.	2.21	2.28	2.28	2.36	2.22	2.29	2.23	2.28	2.20	2.12	2.28	2.35
Min.	1.51	2.03	2.11	2.25	1.59	1.96	1.16	1.8	2.1	2	1.82	2.17

Maximum Combined Cl2 (mg/L)

Avg.	2.42	2.46	2.44	2.49	2.51	2.47	2.42	2.43	2.34	2.26	2.48	2.56
Max.	2.54	2.55	2.58	2.61	2.84	2.65	2.53	2.52	2.49	2.42	2.65	2.76

Mean Combined Cl2 (mg/L)

Avg.	2.35	2.37	2.34	2.41	2.41	2.39	2.33	2.36	2.26	2.18	2.40	2.47
------	------	------	------	------	------	------	------	------	------	------	------	------

Mean Free Cl2 (mg/L)

Avg.	0.11	0.10	0.10	0.08	0.08	0.09	0.10	0.10	0.10	0.09	0.08	0.07
------	------	------	------	------	------	------	------	------	------	------	------	------

Mean Total Cl2 (mg/L)

Avg.	2.45	2.47	2.45	2.49	2.49	2.48	2.43	2.46	2.35	2.28	2.48	2.53
------	------	------	------	------	------	------	------	------	------	------	------	------